

# Certificate of Conformity

Certificate Number: CN-PV-190078

On the basis of the tests undertaken, the samples of the below product have been found to comply with the requirements of the referenced specifications /standards at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture. The manufacturer shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

<b>Applicant:</b>	Shenzhen Growatt New Energy Technology CO.,Ltd 1st East & 3rd Floor of Building A, Building B, Jiayu Industrial Park, #28, GuangHui Road, LongTeng Community, Shiyan Street, Baoan District, Shenzhen, P. R. China
<b>Product:</b>	PV Grid inverter
<b>Ratings &amp; Principle Characteristics:</b>	See Appendix to Certificate of Conformity
<b>Models:</b>	MAX 50KTL3 LV, MAX 60KTL3 LV, MAX 70KTL3 LV, MAX 75KTL3 LV, MAX 80KTL3 LV, MAX 60KTL3 MV, MAX 70KTL3 MV, MAX 80KTL3 MV
<b>Brand Name:</b>	Growatt
<b>Tested according to:</b>	DIN V VDE V0126-1-1:2013.08 Automatic disconnection device between a generator and the public low-voltage grid Type approved for Greece
<b>Certificate Issuing Office Name &amp; Address:</b>	Intertek Testing Services Ltd. Shanghai 2/F (West Side), No. 707, Zhangyang Road, Free Trade Experimental Area, Shanghai, P. R. China
<b>Test Reports No:</b>	191120148GZU-003

Additional information in Appendix.



**Signature**

**Certification Manager: Grady Ye**

**Date: 04 December 2019**

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-190078.

Ratings & Principle Characteristics:

Model	MAX 80KTL3 LV	MAX 60KTL3 MV	MAX 70KTL3 MV	MAX 80KTL3 MV
Max. PV voltage	1100 d.c.V			
PV voltage range	200-1000 d.c.V			
PV Isc	32 d.c.A*7	32 d.c.A*6	32 d.c.A*7	
Max. input current	26 d.c.A*7	26 d.c.A*6	26 d.c.A*7	
Max. output power	80000W	60000W	70000W	80000W
Max. apparent power	88800VA	66600VA	77700VA	88800VA
Nominal output voltage	3W/N/PE 230/400 a.c.V	3W/N/PE or 3W+PE 277/480 a.c.V		
Max. output current	128.8 a.c.A	80.2 a.c.A	93.6 a.c.A	107.0 a.c.A
Nominal output frequency	50Hz			
Power factor range	0.8Leading ~ 0.8Lagging			
Safety level	Class I			
Ingress Protection	IP65			
Operation Ambient Temperature	-25°C - +60°C			
Software Version	TI1.0			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-190078.

Ratings & Principle Characteristics:

Model	MAX 50KTL3 LV	MAX 60KTL3 LV	MAX 70KTL3 LV	MAX 75KTL3 LV
Max. PV voltage	1100 d.c.V			
PV voltage range	200-1000 d.c.V			
PV Isc	32 d.c.A*6		32 d.c.A*7	
Max. input current	26 d.c.A*6		26 d.c.A*7	
Max. output power	50000W	60000W	70000W	75000W
Max. apparent power	55500VA	66600VA	77700VA	83300VA
Nominal output voltage	3W/N/PE 230/400 a.c.V			
Max. output current	80.5 a.c.A	96.6 a.c.A	112.7 a.c.A	120.8 a.c.A
Nominal output frequency	50Hz			
Power factor range	0.8Leading ~ 0.8Lagging			
Safety level	Class I			
Ingress Protection	IP65			
Operation Ambient Temperature	-25°C - +60°C			
Software Version	TI1.0			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.